


PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Memo No. VBPHC/34/2026

Dated: 19.01.2026

It is certified that an inspection team headed by **Dr. Prasun Jana**, Block Medical Officer of Health from Vidyasagar Block Primary Health Centre, Birsingha, Ghatal, Paschim Medinipur inspected the **Pandit Iswar Chandra Vidyasagar Mission** at Marichya, Ghatal, Paschim Medinipur on 02.01.2026 and on the basis of Water Test Report bearing no. **8536/2026** dated 03.04.2025 of Jhargram District Water Testing Laboratory certified that the **Pandit Iswar Chandra Vidyasagar Mission** has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/ U.T. Govt.

This certificate is valid for a period of 19th January, 2026 to 18th January, 2028.


19/01/2026
Block Medical Officer of Health
Vidyasagar BPHC, Birsingha
Paschim Medinipur

Name : Dr. Prasun Jana

Designation : Block Medical Officer of Health

Address : Birsingha , Ghatal, Paschim Medinipur.

To

PANDIT ISWAR CHANDRA VIDYASAGAR MISSION
Vill-Marichya, P.O.-Dandipur, P.S.-Ghatal,
Dist- Paschim Medinipur, W.B., Pin- 721222.


04.06.25

**JHARGRAM DISTRICT WATER TESTING LABORATORY**

Jhargram Division, Public Health Engineering Dte.
Government of West Bengal.

TEST CERTIFICATE

Report No-Misc/8536/2025		Date of Reporting-03.04.2025
Name of the Organization	Pandit Iswar Chandra Vidyasagar Mission, Ghatal, Paschim Medinipur, West Bengal.	
Ref Memo No-		
Location- Belpahari, Jhargram, Pin-721501 Near Hadra Overhead Reservoir.		
Sample Received on:- 06.03.2025		Date of Collection:- 06.03.2025
Sample Collected by:- Sampling Assistant		Type of Sample:- Drinking Water
Analysis:	Date of Starting:- 06.03.2025	Date of Completion:- 01.04.2025

1. Physical & Chemical Test Findings : (Sample Received As Tested)


SL. No	Parameters	Desirable Limit* (Max)	Permissible Limit* in absence of alternate source	Results
1.	Turbidity,(NTU)	1.00	5.00	0.55
2.	pH Value	6.5 to 8.5	No Relaxation	8.46
3.	Total Dissolved Solid,mg/l	500.00	2000.00	-
4.	Total Hardness (as TH), mg/l	200.00	600.00	200
5.	Fluoride (as F) mg/l	1.0	1.5	-
6.	Iron (as Fe),mg/l	1.0	No Relaxation	0.00
7.	Chloride (as Cl),mg/l	250.00	1000.00	-
8.	Arsenic (as As),mg/l	0.01	No Relaxation	-
9.	Manganese (as Mn),mg/l	0.10	0.30	0.15


** Drinking Water-Specification-IS: 10500:2012


2. Bacteriological Test Findings: (Sample Tested as Received)


SL. No	Organisms	IS 10500:2012(Limit)	Result			
			Sample 1	Sample 2	Sample 3	Sample 4
1.	Coliform Bacteria	Shall not be detectable in any 100 ml sample	Absent			
2.	Escherichia coli	Shall not be detectable in any 100 ml sample	Absent			

Comment if any: Sample Bacteriological Test Findings: (Sample Tested as Received)


Chemist
Jhargram District Laboratory


Bacteriologist
Jhargram District Laboratory


Assistant Engineer(HQ)
Jhargram Division, P.H.E.


Principal
Pandit Iswar Chandra Vidyasagar Mission
Affiliated To CBSE
Affiliation No.2430290, School Code-16009
Marichya :: Ghatal :: Paschim Medinipur